


- NOTES:
1. GAS/DIESEL USE
  2. ENVIROLASTIC 940 DTM POLYASPARTIC URETHANE COATING FOR HIGH PERFORMANCE FINISH (MEMCO GREY)
  3. UL 2085 LABELED AND LISTED
  4. 2 HOUR RATING TESTED TO SWRI 97-04 NFPA 30 A FIRE RESISTANT TANK
  5. ENGINEERED HURRICANE TIE-DOWN
  6. LEAD TIME IS DEPENDENT ON IMMEDIATE APPROVAL



\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED  
DRAWING, WHICH MUST BE RETURNED BEFORE  
PRODUCTION CAN BEGIN\*

#



STI  
SwRI  
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP		4/18/2019		MEMCO, INC	
MEMCO REP				<div>envirosafe™</div> <div>10,000 GALLON FIREGUARD DISPENSER SYSTEM</div> <div>ABOVE-GROUND FUEL SYSTEMS</div>	
QUOTE #					
Customer Approval Signature				SIZE C	DWG NO
CUSTOMER REQUESTED COMPLETION DATE :				SCALE	REV
				SHEET 1 OF 5	

PARTS LIST		
ITEM	QTY	DESCRIPTION
1	1	10,000 FIREGUARD TANK MOUNTED ON SADDLES
2	1	18" MANWAY FOR EASY INNER TANK ACCESSIBILITY
3	2	8 IN NPT THREADED FLANGE
4	1	6 IN NPT THREADED FLANGE
5	5	4 IN NPT THREADED FLANGE
6	7	3" NPT THREADED FLANGE (CONCRETE PORT)
7	1	3 IN NPT THREADED FLANGE
8	1	2 IN NPT THREADED FLANGE
9	4	LIFTING LUG
10	2	VENT EMERGENCY 8IN 8OZ./SQ.IN- MALE THREAD- w/O-RING
11	1	INTERSTITIAL LEAK GAUGE
12	1	3" UPDRAFT STACK W/3" 354 SLIP ON
13	1	3" OVERFILL PREVENTION VALVE WITH DIFFUSER AND TEST MECHANISM
14	1	MONITORING CAP 2"
15	1	918 CLOCK GAUGE WITH ALARM BOX & STANDARD FLOAT

PARTS LIST		
ITEM	QTY	DESCRIPTION
16	1	3" GROUND LEVEL FILL WITH DUST CAP AND ADAPTOR
17	1	UL LISTED LOCKABLE 3'x4'2"x4' FILL BOX, CROSS BROKEN FOR EASY DRAINAGE, 2" VENT AND 1/2" BALL VALVE
18	1	STEP LADDER MOUNTED TO THE BOX ON BOX WITH HANDRAILS
19	1	FE PETRO 3/4 HP w/RISER, 88IN - 149IN (240V 1 PH)
20	1	DISPENSER BENNETT SINGLE PRODUCT 3711SNR-18-J-P-SO
21	1	NEMA 7 EXPLOSION PROOF BOX FOR CBS SWITCH
22	1	2" SHEAR VALVE
23	1	VALVE BALL 2IN
24	1	2" ANTI-SYPHON VALVE
25	1	BOX SINGLE PHASE CONTROL w/ SWITCH & LOCKOUT 120V COIL (NOT SHOWN)
26	1	TANK DECAL KIT (NOT SHOWN)
27	1	TOUCH UP PAINT (NOT SHOWN & SHIPPED SEPARATELY)



\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN\*


#

SHELL THICKNESS: 1/4"  
HEAD THICKNESS: 5/16"

STI  
SwRI  
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP MEMCO REP	4/18/2019	MEMCO, INC			
QUOTE #		<div>envirosafe™</div> <div>10,000 GALLON FIREGUARD DISPENSER SYSTEM</div> <div>ABOVE-GROUND FUEL SYSTEMS</div>			
Customer Approval Signature		SIZE C	DWG NO		REV
		SCALE			
		SHEET 2 OF 5			



\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN\*

#

This document and all information and design thereon are the property of EnviroSafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from EnviroSafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by EnviroSafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

STI  
SwRI  
UL

DRAWN BY AP	4/18/2019	MEMCO, INC	
MEMCO REP		<div>envirosafe™</div> <div>10,000 GALLON FIREGUARD DISPENSER SYSTEM</div> <div>ABOVE-GROUND FUEL SYSTEMS</div>	
QUOTE #			
Customer Approval Signature		SIZE C	DWG NO
		SCALE	REV
			SHEET 3 OF 5