


- NOTES:
1. GAS/DIESEL USE
  2. ENVIROLASTIC 940 DTM POLYASPARTIC URETHANE COATING FOR HIGH PERFORMANCE FINISH (MEMCO GREY)
  3. UL 2085 LABELED AND LISTED
  4. 2 HOUR RATING TESTED TO SWRI 97-04 NFPA 30 A FIRE RESISTANT TANK
  5. ENGINEERED HURRICANE TIE-DOWN
  6. LEAD TIME IS DEPENDENT ON IMMEDIATE APPROVAL




\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED  
DRAWING, WHICH MUST BE RETURNED BEFORE  
PRODUCTION CAN BEGIN\*



#

STI  
SwRI  
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP	7/29/2019	MEMCO, INC	
MEMCO REP		 5,000 GALLON FIREGUARD DISPENSER SYSTEM	
QUOTE #			
Customer Approval Signature		SIZE C	DWG NO
CUSTOMER REQUESTED COMPLETION DATE :		SCALE	REV
		SHEET 1 OF 5	

PARTS LIST			PARTS LIST		
ITEM	QTY	DESCRIPTION	ITEM	QTY	DESCRIPTION
1	1	5,000 GALLON FIREGUARD TANK MOUNTED ON SADDLES	15	1	918 CLOCK GAUGE WITH ALARM BOX & STANDARD FLOAT
2	1	18" MANWAY FOR EASY INNER TANK ACCESSIBILITY	16	1	3" GROUND LEVEL FILL WITH DUST CAP AND ADAPTOR
3	2	8 IN NPT THREADED FLANGE	17	1	UL LISTED LOCKABLE 3'x4'2"x4' FILL BOX, CROSS BROKEN FOR EASY DRAINAGE, 2" STACK VENT AND 1/2" BALL VALVE
4	1	6 IN NPT THREADED FLANGE	18	1	FE PETRO 3/4 HP w/RISER, 88IN - 149IN (240V 1 PH)
5	5	4 IN NPT THREADED FLANGE	19	1	STEP LADDER MOUNTED ON BOX TO ACCESS TOP OF TANK WITH HANDRAIL SYSTEM AND SAFETY SHIELD
6	3	3" NPT THREADED FLANGE (CONCRETE PORT)	20	1	BENNETT DISPENSER SINGLE PRODUCT 3711SNR-18-J-P-SO
7	1	3 IN NPT THREADED FLANGE	21	1	VALVE BALL 2IN
8	2	2 IN NPT THREADED FLANGE	22	1	2" ANTI-SYPHON VALVE
9	2	LIFTING LUG	23	1	NEMA 7 EXPLOSION PROOF BOX FOR CBS SWITCH
10	2	VENT EMERGENCY 8IN 8OZ./SQ.IN- MALE THREAD- w/O-RING	24	1	BOX SINGLE PHASE CONTROL W/SWITCH & LOCKOUT 120 V COIL (NOT SHOWN)
11	1	INTERSTITIAL LEAK GAUGE	25	1	TANK DECAL KIT (NOT SHOWN)
12	1	3" UPDRAFT STACK W/3" 354 SLIP ON	26	1	TOUCH UP PAINT (NOT SHOWN AND SHIPPED SEPARATELY)
13	1	3" OVERFILL PREVENTION VALVE WITH TEST MECHANISM AND DIFFUSER			
14	1	MONITORING CAP 2"			



\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN\*



#

SHELL THICKNESS: 1/4"  
HEAD THICKNESS: 5/16"

STI  
SwRI  
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP MEMCO REP	7/29/2019	MEMCO, INC		
QUOTE #		<div>envirosafe™</div> <div>5,000 GALLON FIREGUARD DISPENSER SYSTEM</div> <div>ABOVE-GROUND FUEL SYSTEMS</div>		
Customer Approval Signature		SIZE C	DWG NO	REV
		SCALE		
		SHEET 2 OF 5		




\*LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN\*

#

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

STI  
SwRI  
UL

DRAWN BY AP	7/29/2019	MEMCO, INC	
MEMCO REP		 5,000 GALLON FIREGUARD DISPENSER SYSTEM	
QUOTE #			
		SIZE C	DWG NO
Customer Approval Signature		SCALE	REV
		SHEET 3 OF 5	