


- NOTES:
- 1. GAS USE
 - 2. ENVIROLASTIC 940 LV POLYASPARTIC COATING FOR HIGH PERFORMANCE FINISH (WHITE)
 - 3. UL 2085 LABELED AND LISTED
 - 4. 2 HOUR RATING TESTED TO SwRI 97-04 NFPA 30 A FIRE RESISTANT TANK
 - 5. TIE-DOWN POINTS ON SADDLES
 - 6. LEAD TIME IS DEPENDENT ON IMMEDIATE APPROVAL



WHITE

CALCULATED WEIGHT:

32,300 LB±

FIREGUARD
TANK CAPACITY :10,000 GALLONS

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copies without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Right Reserved. Memco, Inc.

#22052

STI 46851	SwRI FG203541	UL D86742923
--------------	------------------	-----------------

IT IS THE CLIENT'S RESPONSIBILITY TO ENSURE SYSTEM COMPLIANCE WITH APPLICABLE REGULATIONS.


APPROVED BY:

CUSTOMER REDACTED

ER. VERSION # :6291	SALES ORDER # :00010762
---------------------	-------------------------

AUTHOR	AP
MEMCO REP	TS
DATE	9/12/2022
SIZE D	REV
	SHEET 1 OF 6

envirosafeTM
ABOVE-GROUND FUEL SYSTEMS



This document and all information and design thereon are the property of EnviroSAFE Fuel Systems. This document is confidential and must not be made public or copies without written authorization from EnviroSAFE and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by EnviroSAFE. Acceptance of possession of this document constitutes full agreement with the above conditions. All Right Reserved. Memco, Inc.

#22052

STI 46851	SwRI FG203541	UL D86742923
--------------	------------------	-----------------

IT IS THE CLIENT'S RESPONSIBILITY TO ENSURE SYSTEM COMPLIANCE WITH APPLICABLE REGULATIONS.


APPROVED BY:

CUSTOMER REDACTED

ER. VERSION #:6291	SALES ORDER #:00010762
--------------------	------------------------

AUTHOR	AP
MEMCO REP	TS
DATE	9/12/2022
SIZE D	REV
	SHEET 2 OF 6





SHELL THICKNESS: 1/4"
HEAD THICKNESS: 5/16"

This document and all information and design thereon are the property of EnviroSafe Fuel Systems. This document is confidential and must not be made public or copies without written authorization from EnviroSafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by EnviroSafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Right Reserved. Memco, Inc.

#22052

STI 46851	SwRI FG203541	UL D86742923
--------------	------------------	-----------------

IT IS THE CLIENT'S RESPONSIBILITY TO ENSURE SYSTEM COMPLIANCE WITH APPLICABLE REGULATIONS.

APPROVED BY:

CUSTOMER REDACTED

ER. VERSION #:	6291	SALES ORDER #:	00010762
----------------	------	----------------	----------

AUTHOR	AP
MEMCO REP	TS
DATE	9/12/2022
SIZE D	REV
	SHEET 3 OF 6

A SEALING COMPOUND IS NOT INSTALLED IN SEAL-OFF. IT NEEDS TO BE INSTALLED ON SITE BEFORE THE INITIAL START-UP OF THE TANK.

